



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.

Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers

CTI Certification Validation Number C11F-92R20

August 13, 2021 (Revision 20)

3000A

3240A-GM	3412A-GM	3473A-HM	3872A-KM	3583A-JM	31130A-LM
3240A-HM	3412A-HM	3473A-JM	3872A-LM	3583A-KM	31130A-MM
3240A-JM	3412A-JM	3473A-KM	3872A-MM	3583A-LM	31130A-NM
3240A	3412A-KM	3473A-LM	3872A-NM	3583A-MM	31130A-OM
3272A	3412A-LM	3473A-MM	3872A-OM	3583A	31130A-PM
3299A	3412A-MM	3473A	3872A-PM	3618A	31130A-QM
	3412A	3501A	3872A	3676A	31130A-RM
	3436A		3923A	3725A	31130A
			3970A	3719A	31212A
3333A-GM	3455A-GM	3552A-JM	3918A-KM	31132A-LM	31213A-MM
3333A-HM	3455A-HM	3552A-KM	3918A-LM	31132A-MM	31213A-NM
3333A-JM	3455A-JM	3552A-LM	3918A-MM	31132A-NM	31213A-OM
3333A-KM	3455A-KM	3552A-MM	3918A-NM	31132A-OM	31213A-PM
3333A-LM	3455A-LM	3552A-NM	3918A-OM	31132A-PM	31213A-QM
3333A	3455A-MM	3552A	3918A-PM	31132A-QM	31213A-RM
3358C	3455A	3604A	3918A-QM	31132A-RM	31213A
3379A	3482A	3648A	3918A	31132A	31301A
	3527A	3672A	3984A	31186A	31396A
3371A-GM		3728A-KM	3985A-LM		
3371A-HM		3728A-LM	3985A-MM		
3371A-JM		3728A-MM	3985A-NM		
3371A-KM		3728A-NM	3985A-OM		
3371A-LM		3728A-OM	3985A-PM		
3371A-MM		3728A	3985A-QM		
3371A		3781A	3985A		
3393A		3828A	31056A		
3430A		3871A	31133A		

Model numbers listed above are for units with standard fans.
Add suffix /Q to any model number for units with optional low sound fans.

See Series 3000A, C, & D Footnotes for Additional Options and Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

3000C

3240C-GM	3412C-GM	3473C-HM	3872C-KM	3583C-JM	31130C-LM
3240C-HM	3412C-HM	3473C-JM	3872C-LM	3583C-KM	31130C-MM
3240C-JM	3412C-JM *	3473C-KM *	3872C-MM	3583C-LM	31130C-NM
3240C	3412C-KM *	3473C-LM *	3872C-NM	3583C-MM *	31130C-OM
3272C	3412C-LM *	3473C-MM *	3872C-OM *	3583C	* 31130C-PM *
3299C	3412C-MM *	3473C	* 3872C-PM *	3618C	* 31130C-QM *
	3412C *	3501C	* 3872C	* 3676C	* 31130C-RM *
	3436C *		3923C	* 3725C	* 31130C *
			3970C	* 3719C	* 31212C *
3333C-GM	3455C-GM	3552C-JM	3918C-KM	31132C-LM	31213C-MM
3333C-HM	3455C-HM	3552C-KM	3918C-LM	31132C-MM	31213C-NM
3333C-JM	3455C-JM	3552C-LM *	3918C-MM	31132C-NM	31213C-OM
3333C-KM	3455C-KM *	3552C-MM *	3918C-NM	31132C-OM	31213C-PM
3333C-LM	3455C-LM *	3552C-NM *	3918C-OM *	31132C-PM *	31213C-QM *
3333C	3455C-MM *	3552C	* 3918C-PM *	31132C-QM *	31213C-RM *
3358C	3455C	* 3604C	* 3918C-QM *	31132C-RM *	31213C *
3379C	3482C *	3648C	* 3918C	* 31132C	* 31301C *
	3527C *	3672C	* 3984C	* 31186C	* 31396C *
3371C-GM		3728C-KM	3985C-LM		
3371C-HM		3728C-LM	3985C-MM		
3371C-JM		3728C-MM	3985C-NM		
3371C-KM		3728C-NM *	3985C-OM		
3371C-LM		3728C-OM *	3985C-PM *		
3371C-MM		3728C	* 3985C-QM *		
3371C		3781C	* 3985C		
3393C		3828C	* 31056C		
3430C		3871C	* 31133C		

Model numbers listed above are for units with standard fans.

Add suffix /Q to any model number for units with optional low sound fans.

Add suffix /W to any model number indicated with "*" for optional Whisper Quiet Fans.

See Series 3000A, C, & D Footnotes for Additional Options and Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.

Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers

CTI Certification Validation Number C11F-92R20

August 13, 2021 (Revision 20)

3000D (S3-D)

S3-D240HL	S3-D412HL	S3-D473JL	S3-D872LL	S3-D583JL	S3-D1213ML
S3-D240GL	S3-D412GL	S3-D473HL	S3-D872KL	S3-D583KL	S3-D1213NL
S3-D240JL	S3-D412JL	S3-D473KL	S3-D872ML	S3-D583LL	S3-D1213OL
S3-D240L	S3-D412KL	S3-D473LL	S3-D872NL	S3-D583ML	S3-D1213PL
S3-D272L	S3-D412LL	S3-D473ML	S3-D872OL	S3-D583L	S3-D1213QL
S3-D299L	S3-D412ML	S3-D473L	S3-D872PL	S3-D618L	S3-D1213RL
	S3-D412L	S3-D501L	S3-D872L	S3-D676L	S3-D1213L
	S3-D436L		S3-D923L	S3-D725L	S3-D1301L
			S3-D970L		
S3-D333GL	S3-D455GL	S3-D552JL	S3-D985ML	S3-D1132ML	
S3-D333HL	S3-D455HL	S3-D552KL	S3-D985LL	S3-D1132LL	
S3-D333JL	S3-D455JL	S3-D552LL	S3-D985NL	S3-D1132NL	
S3-D333KL	S3-D455KL	S3-D552ML	S3-D985OL	S3-D1132OL	
S3-D333LL	S3-D455LL	S3-D552NL	S3-D985PL	S3-D1132PL	
S3-D333L	S3-D455ML	S3-D552L	S3-D985QL	S3-D1132QL	
S3-D358L	S3-D455L	S3-D604L	S3-D985L	S3-D1132RL	
S3-D379L	S3-D482L	S3-D648L	S3-D1056L	S3-D1132L	
	S3-D527L	S3-D672L			
		S3-D728KL			
		S3-D728LL			
		S3-D728ML			
		S3-D728NL			
		S3-D728OL			
		S3-D728L			
		S3-D781L			
		S3-D828L			

Model numbers listed above are for units with low sound fans and ISO fan guards as standard.

See Series 3000A, C, & D Footnotes for Additional Options and Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.

Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers

CTI Certification Validation Number C11F-92R20

August 13, 2021 (Revision 20)

Series 3000 A, C, & D

Optional Accessories and Construction Table – Certification Status

Option	Suffix Note 1	CTI Certified	Capacity Adjustment Required
Access Platforms – External	L	Yes	No
Service Platform – Internal	P	Yes	No
Energy-Miser® Fan System	none	Yes	No
Discharge Sound Attenuation	Z	Yes	No
Two Drift Eliminator Sets	E	Yes	Yes, Note 2
Gear Drive	G	Yes	No
Low Sound Fan	/Q	Yes	Yes, Note 3
Whisper Quiet Fan	/W	Yes	Yes, Note 4
Non-Standard Motor Size	M	Note 5	Yes, Note 5
Velocity Recovery Fan Stack	V	Yes	Yes, Note 6
European Models	none	Yes	Yes, Note 7
Structural Upgrade	S	Yes	Yes, Note 8
Not CTI Certified	X	No	Note 9
Alternate Drive	D	Yes	Note 10

Footnotes:

- Typically no suffix is used for an accessory or modification that does not affect capacity.
- Two sets of drift eliminators incur a capacity reduction of 2% relative to the standard unit.
- Low Sound Fans on Series 3000A, C & D cooling towers incur a capacity reduction of 3% relative to the same unit with a standard fan.
- Whisper Quiet Fans on applicable models of Series 3000A, C & D cooling towers incur a capacity reduction of 5% relative to the same unit with a standard fan.
- Units with non-standard motor sizes are certified only if they are listed in the Data of Record and sold at the revised capacity listed in the rating table.
- Velocity Recovery Fan Stacks increase the capacity of the tower by 3 to 6%, depending upon the model and the operating conditions. Refer to the Model Selection tables at the BAC website (www.BaltimoreAircoil.com) to determine the effect on a particular model at the specific operating condition.
- European models (beginning with S3-D) utilize low sound fans as standard and a different fan guard from the North American models. Therefore they incur a capacity reduction of 5%. (3% for low sound fans plus 2% for fan guard) compared to the North American models.
- The structural upgrade construction option incurs a capacity reduction of 5% for the single piece units and 3% for the two piece units.
- This suffix is affixed to model numbers of units that are not CTI Certified, due either to application or product accessories or modifications.
- Available on 3000C models with between 20 and 100 total fan HP. Direct Drive fan system without gearbox or belt will increase the capacity by 1.3% relative to the standard unit.



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

3000E (S3E)

XES3E-8518-05G	XES3E-1020-06G	XES3E-1222-06H	XES3E-1222-12K	XES3E-1424-07J	XES3E-1424-13L
XES3E-8518-05H	XES3E-1020-06H	XES3E-1222-06J	XES3E-1222-12L	XES3E-1424-07K	XES3E-1424-13M
XES3E-8518-05J	XES3E-1020-06J *	XES3E-1222-06K *	XES3E-1222-12M	XES3E-1424-07L	XES3E-1424-13N
XES3E-8518-05K	XES3E-1020-06K *	XES3E-1222-06L *	XES3E-1222-12N	XES3E-1424-07M *	XES3E-1424-13O
S3E-8518-05L	XES3E-1020-06L *	S3E-1222-06M *	XES3E-1222-12O *	XES3E-1424-07N *	XES3E-1424-13P *
S3E-8518-05M	S3E-1020-06M *	S3E-1222-06N *	S3E-1222-12P *	S3E-1424-07O *	S3E-1424-13Q *
	S3E-1020-06N *	S3E-1222-06O *	S3E-1222-12Q *	S3E-1424-07P *	S3E-1424-13R *
	S3E-1020-06O *		S3E-1222-12R *	S3E-1424-07Q *	S3E-1424-13S *
			S3E-1222-12S *	S3E-1424-07R *	S3E-1424-13T *
XES3E-8518-06G	XES3E-1020-07G	XES3E-1222-07J	XES3E-1222-13K	XES3E-1424-12L	XES3E-1424-14M
XES3E-8518-06H	XES3E-1020-07H	XES3E-1222-07K	XES3E-1222-13L	XES3E-1424-12M	XES3E-1424-14N
XES3E-8518-06J	XES3E-1020-07J	XES3E-1222-07L *	XES3E-1222-13M	XES3E-1424-12N	XES3E-1424-14O
XES3E-8518-06K	XES3E-1020-07K *	XES3E-1222-07M *	XES3E-1222-13N	XES3E-1424-12O	XES3E-1424-14P
S3E-8518-06L	XES3E-1020-07L *	S3E-1222-07N *	XES3E-1222-13O *	XES3E-1424-12P *	S3E-1424-14Q *
S3E-8518-06M	S3E-1020-07M *	S3E-1222-07O *	S3E-1222-13P *	S3E-1424-12Q *	S3E-1424-14R *
S3E-8518-06N	S3E-1020-07N *	S3E-1222-07P *	S3E-1222-13Q *	S3E-1424-12R *	S3E-1424-14S *
S3E-8518-06O	S3E-1020-07O *	S3E-1222-07Q *	S3E-1222-13R *	S3E-1424-12S *	S3E-1424-14T *
	S3E-1020-07P *	S3E-1222-07R *	S3E-1222-13S *	S3E-1424-12T *	S3E-1424-14U *
					S3E-1424-14W *
XES3E-8518-07G		XES3E-1222-10K	XES3E-1222-14L		
XES3E-8518-07H		XES3E-1222-10L	XES3E-1222-14M		
XES3E-8518-07J		XES3E-1222-10M	XES3E-1222-14N		
XES3E-8518-07K		XES3E-1222-10N *	XES3E-1222-14O		
XES3E-8518-07L		XES3E-1222-10O *	S3E-1222-14P *		
S3E-8518-07M		S3E-1222-10P *	S3E-1222-14Q *		
S3E-8518-07N		S3E-1222-10Q *	S3E-1222-14R *		
S3E-8518-07O		S3E-1222-10R *	S3E-1222-14S *		
S3E-8518-07P		S3E-1222-10S *	S3E-1222-14T *		

Model numbers listed above are for units with standard fans.

Add suffix /L to any model number for units with optional low sound fans.

Add suffix /W or /A to any model number indicated with "*" for units with optional Whisper Quiet Fans.

See Series 3000E Footnotes for Additional Options and Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
 Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

Series 3000 E

Optional Accessories and Construction Table – Certification Status

Option	Suffix Note 1	CTI Certified	Capacity Adjustment Required
Access Platforms – External	None	Yes	No
Service Platform – Internal	None	Yes	No
Air Intake Screens	None	Yes	No
Combined Inlet Shields	None	Yes	No
Baltiguard® Fan System	None	Yes	No
Discharge Sound Attenuation	None	Yes	No
High Temperature Fill	None	Yes	No
Gear Drive	None	Yes	No
Two Drift Eliminator Sets	E	Yes	Yes, Note 2
EU Fan Guard	H	Yes	Yes, Note 3
FM Listed	Y	Yes	No
Low Sound Fan	L	Yes	Yes, Note 5
Whisper Quiet Fan	W or A	Yes	Yes, Note 6
Non-Standard Motor Size	None	Note 7	Yes, Note 7
Velocity Recovery Fan Stack	V	Yes	Yes, Note 8
Structural Upgrade	S	Yes	Yes, Note 9
Not CTI Certified	X	No	Note 10
Alternate Drive	D	Yes	Yes, Note 11
Footnotes:			
1. Typically no suffix is used for an accessory or modification that does not affect capacity.			
2. Two sets of drift eliminators incur a capacity reduction of 2% relative to the standard unit.			
3. EU fan guards, which have different heights than North American fan guards and may require a fan cowl extension, have a capacity reduction of 2%.			
4. Multiple cell models of the single cell models above are also available and CTI certified but not listed			
5. Low Sound Fans on Series 3000E cooling towers incur a capacity reduction of 3% relative to the same unit with a standard fan.			
6. Whisper Quiet Fans on applicable models of Series 3000E cooling towers incur a capacity reduction of 0% (Suffix A) or 5% (suffix W) relative to the same unit with a standard fan..			
7. Units with non-standard motor sizes are certified only if they are listed in the Data of Record and sold at the revised capacity listed in the rating table.			
Continued on Next Page			



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • <http://www.cti.org>

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

Series 3000 E

Optional Accessories and Construction Table – Certification Status

8.	Velocity Recovery Fan Stacks increase the capacity of the tower by 3 to 6%, depending upon the model and the operating conditions. Refer to the Model Selection tables at the BAC website (www.BaltimoreAircoil.com) to determine the effect on a particular model at the specific operating condition.
9.	The structural upgrade construction option incurs a capacity reduction of 5% for the single piece units and 3% for the two piece units.
10.	This suffix is affixed to model numbers of units that are not CTI Certified, due either to application or product accessories or modifications.
11.	Available between 20 and 100 total fan HP. Direct Drive fan system without gearbox or belt will increase the capacity by 1.3% relative to the standard unit.



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

Series 1500 – First Generation Models

15146-EM	15162-EM	15200-FM	15214-FM	15296-GM	15310-GM
15146-FM	15162-FM	15200-GM	15214-GM	15296-HM	15310-HM
15146-GM	15162-GM	15200-HM	15214-HM	15296-JM	15310-JM
15146-HM	15162-HM	15200-JM	15214-JM	15296-KM	15310-KM
15146	15162	15200	15214	15296	15310
15160	15177	15227	15245	15325	15340
15176	15201	15250	15270	15350	15365
	15219		15282	15368	15385
					15425

Series 1500 1st Generation Optional Accessories and Constructions – Certification Status

Option	Suffix Note 1	CTI Certified	Capacity Adjustment Required
Access Platform – External	none	Yes	No
Energy-Miser® Fan System	none	Yes	No
Low Sound Fan	Q	Yes	Note 2
“Whisper Quiet” Low Sound Fan	WQ	Yes	Note 3
Non-Standard Motor Size	M	Note 4	Yes, Note 4
Discharge Sound Attenuation	none	Yes	No
Unit not CTI Certified	X	No	Note 5

Note: 1. Typically no suffix is used for an accessory or modification that does not affect capacity.
2. Low sound fans on Series 1500 Cooling Towers incur a capacity reduction of 3% relative to the same unit with a standard fan.
3. Whisper Quiet low sound fans on Series 1500 Cooling Towers use a high solidity fan running at reduced speed and incur a capacity reduction of 3 % relative to the same unit with a standard fan.
4. Units with non-standard motor sizes are certified only if they are listed in the Data of Record and sold at the revised capacity listed in the rating table.
5. This suffix is affixed to model numbers of units that are not CTI Certified, due either to application or product accessories or modifications.



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

S15E – North American Models

XES15E-1285-06EN	XES15E-1212-07EN	XES15E-1212-11EN	XES15E-1218-07EN	XES15E-1218-11EN
XES15E-1285-06FN	XES15E-1212-07FN	XES15E-1212-11FN	XES15E-1218-07FN	XES15E-1218-11FN
XES15E-1285-06GN	XES15E-1212-07GC	XES15E-1212-11GC	XES15E-1218-07GN	XES15E-1218-11GN
XES15E-1285-06HN	XES15E-1212-07GN	XES15E-1212-11GN	XES15E-1218-07HN	XES15E-1218-11HN
S15E-1285-06JN	XES15E-1212-07HC	XES15E-1212-11HC	S15E-1218-07JN	XES15E-1218-11JN
S15E-1285-06KN	XES15E-1212-07HN	XES15E-1212-11HN	S15E-1218-07KN	S15E-1218-11KN
S15E-1285-06LN	S15E-1212-07JN	XES15E-1212-11JN	S15E-1218-07LC	S15E-1218-11LC
	S15E-1212-07KN	S15E-1212-11KN		S15E-1218-11LN
XES15E-1285-07EN	S15E-1212-07LC	S15E-1212-11LC	XES15E-1218-09EN	S15E-1218-11MN
XES15E-1285-07FN		S15E-1212-11LN	XES15E-1218-09FN	
XES15E-1285-07GN	XES15E-1212-09EN	S15E-1212-11MN	XES15E-1218-09GN	XES15E-1218-12EN
XES15E-1285-07HN	XES15E-1212-09FN		XES15E-1218-09HN	XES15E-1218-12FN
XES15E-1285-07JN	XES15E-1212-09GC	XES15E-1212-12EN	S15E-1218-09JN	XES15E-1218-12GN
S15E-1285-07KN	XES15E-1212-09GN	XES15E-1212-12FN	S15E-1218-09KN	XES15E-1218-12HN
S15E-1285-07LN	XES15E-1212-09HC	XES15E-1212-12GC	S15E-1218-09LC	XES15E-1218-12JN
S15E-1285-07MN	XES15E-1212-09HN	XES15E-1212-12GN	S15E-1218-09LN	S15E-1218-12KN
	S15E-1212-09JN	XES15E-1212-12HC		S15E-1218-12LC
XES15E-1285-09FN	S15E-1212-09KN	XES15E-1212-12HN	XES15E-1218-10EN	S15E-1218-12LN
XES15E-1285-09GN	S15E-1212-09LC	XES15E-1212-12JN	XES15E-1218-10FN	S15E-1218-12MN
XES15E-1285-09HN	S15E-1212-09LN	S15E-1212-12KN	XES15E-1218-10GN	
XES15E-1285-09JN		S15E-1212-12LC	XES15E-1218-10HN	
S15E-1285-09KN	XES15E-1212-10EN	S15E-1212-12LN	XES15E-1218-10JN	
S15E-1285-09LN	XES15E-1212-10FN	S15E-1212-12MN	S15E-1218-10KN	
S15E-1285-09MN	XES15E-1212-10GC		S15E-1218-10LC	
	XES15E-1212-10GN		S15E-1218-10LN	
XES15E-1285-10FN	XES15E-1212-10HC		S15E-1218-10MN	
XES15E-1285-10GN	XES15E-1212-10HN			
XES15E-1285-10HN	XES15E-1212-10JN			
XES15E-1285-10JN	S15E-1212-10KN			
XES15E-1285-10KN	S15E-1212-10LC			
S15E-1285-10LN	S15E-1212-10LN			
S15E-1285-10MN	S15E-1212-10MN			
S15E-1285-10NN				

See Series S15E Footnotes for Additional Options and Constructions Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

S15E – Global Models

XES15E-0809-06DE	XES15E-1012-06EE	XES15E-1212-07EE	XES15E-1212-11EE	XES15E-1218-07EE	XES15E-1218-11EE
XES15E-0809-06EE	XES15E-1012-06FE	XES15E-1212-07FE	XES15E-1212-11FE	XES15E-1218-07FE	XES15E-1218-11FE
XES15E-0809-06FE	XES15E-1012-06GE	XES15E-1212-07GE	XES15E-1212-11GE	XES15E-1218-07GE	XES15E-1218-11GE
S15E-0809-06GE	S15E-1012-06HE	XES15E-1212-07HE	XES15E-1212-11HE	XES15E-1218-07HE	XES15E-1218-11HE
S15E-0809-06HE	S15E-1012-06JE	S15E-1212-07JE	XES15E-1212-11JE	S15E-1218-07JE	XES15E-1218-11JE
	S15E-1012-06KE	S15E-1212-07KE	S15E-1212-11KE	S15E-1218-07KE	S15E-1218-11KE
XES15E-0812-06DE		S15E-1212-07L1	S15E-1212-11LE	S15E-1218-07L1	S15E-1218-11L1
XES15E-0812-06EE	XES15E-1012-09EE		S15E-1212-11ME		S15E-1218-11LE
XES15E-0812-06FE	XES15E-1012-09FE	XES15E-1212-09EE		XES15E-1218-09EE	S15E-1218-11ME
S15E-0812-06GE	XES15E-1012-09GE	XES15E-1212-09FE	XES15E-1212-12EE	XES15E-1218-09FE	
S15E-0812-06HE	XES15E-1012-09HE	XES15E-1212-09GE	XES15E-1212-12FE	XES15E-1218-09GE	XES15E-1218-12EE
S15E-0812-06JE	S15E-1012-09JE	XES15E-1212-09HE	XES15E-1212-12GE	XES15E-1218-09HE	XES15E-1218-12FE
	S15E-1012-09KE	S15E-1212-09JE	XES15E-1212-12HE	S15E-1218-09JE	XES15E-1218-12GE
	S15E-1012-09L1	S15E-1212-09KE	XES15E-1212-12JE	S15E-1218-09KE	XES15E-1218-12HE
	S15E-1012-09LE	S15E-1212-09L1	S15E-1212-12KE	S15E-1218-09L1	XES15E-1218-12JE
		S15E-1212-09LE	S15E-1212-12LE	S15E-1218-09LE	S15E-1218-12KE
	XES15E-1012-10EE		S15E-1212-12ME		S15E-1218-12L1
	XES15E-1012-10FE	XES15E-1212-10EE		XES15E-1218-10EE	S15E-1218-12LE
	XES15E-1012-10GE	XES15E-1212-10FE		XES15E-1218-10FE	S15E-1218-12ME
	XES15E-1012-10HE	XES15E-1212-10GE		XES15E-1218-10GE	
	S15E-1012-10JE	XES15E-1212-10HE		XES15E-1218-10HE	
	S15E-1012-10KE	XES15E-1212-10JE		XES15E-1218-10JE	
	S15E-1012-10L1	S15E-1212-10KE		S15E-1218-10KE	
	S15E-1012-10LE	S15E-1212-10L1		S15E-1218-10L1	
		S15E-1212-10LE		S15E-1218-10LE	
	XES15E-1018-09EE	S15E-1212-10ME		S15E-1218-10ME	
	XES15E-1018-09FE				
	XES15E-1018-09GE				
	XES15E-1018-09HE				
	S15E-1018-09JE				
	S15E-1018-09KE				
	S15E-1018-09LE				
	XES15E-1018-10EE				
	XES15E-1018-10FE				
	XES15E-1018-10GE				
	XES15E-1018-10HE				
	S15E-1018-10JE				
	S15E-1018-10KE				
	S15E-1018-10LE				

See Series S15E Footnotes for Additional Options and Constructions Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

Series 1500 "S15E" Optional Accessories and Constructions – Certification Status

Construction Options	Suffix Note 1	CTI Certified	Capacity Adjustment Required
Access Platform - External	None	Yes	No
Access Platform - Internal	None	Yes	No
Direct Drive Motors	None	Yes	No
Air Intake Screens	None	Yes	No
Combined Inlet Shields	None	Yes	No
Baltiguard® Fan System	None	Yes	No
High Temperature Fill	None	Yes	No
Structural Upgrade	None	Yes	No
Non-Standard Motor Size	None	Note 2	Yes, Note 2
Two Drift Eliminator Sets	/E	Yes	Yes, Note 3
Low Sound Fan	/L	Yes	Note 4
“Whisper-Quiet” Low Sound Fan	/W	Yes	Note 5
Single Discharge Sound Attenuation	None	Yes	No
Double Discharge Sound Attenuation	/F	Yes	Yes, Note 6
Parallel Intake Sound Attenuation	/I	Yes	Yes, Note 7
Staggered Intake Sound Attenuation	/G	Yes	Yes, Note 8
FM Listed	Y	Yes	No
Not CTI Certified	/X	No	Note 9

Notes:

- Typically no suffix is used for an accessory or modification that does not affect capacity.
- Units with non-standard motor sizes are certified only if they are listed in Data of Record and sold at the revised capacity listed in the rating table.
- Two sets of drift eliminators incur a capacity reduction of 1% relative to standard unit.
- Low Sound Fans on models with "/L" suffix have a 1 to 4% capacity reduction relative to same unit with standard fan.
- Whisper Quiet low sound fans on models with "/W" suffix have a 1 to 2% capacity reduction relative to same unit with standard fan.
- Double Discharge Sound Attenuation with cross baffles in the air stream incurs a capacity reduction of 7.0% relative to the same unit without this option.
- Parallel Intake Sound Attenuation in the air stream incurs a capacity reduction of 3.0% relative to the same unit without this option.
- Staggered Intake Sound Attenuation in the air stream incurs a capacity reduction of 5.0% relative to the same unit without this option.
- The suffix is affixed to model numbers of units that are not CTI certified, either due to applications or product accessories or modifications to the unit.



COOLING TECHNOLOGY INSTITUTE


P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
 Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

Compass (CPS / CPSC)

Sample Model Number:

CPSC-0716-06G



0716-06G	1020-07K	1222-08K	1424-12N
0716-06H	1020-07L	1222-08L	1424-12O
0716-06J	1020-07M	1222-08M	1424-12P
0716-06K	1020-07N	1222-08N	1424-12Q
0716-06L	1020-07O	1222-08O	1424-12R
0716-06M		1222-08P	1424-12S
		1222-08Q	
0716-07H	1020-08K	1222-09K	1424-14N
0716-07J	1020-08L	1222-09L	1424-14O
0716-07K	1020-08M	1222-09M	1424-14P
0716-07L	1020-08N	1222-09N	1424-14Q
0716-07M	1020-08O	1222-09O	1424-14R
0716-07N	1020-08P	1222-09P	1424-14S
		1222-09Q	1424-14T
		1222-09R	
0817-07J	1020-09K	1222-10L	
0817-07K	1020-09L	1222-10M	
0817-07L	1020-09M	1222-10N	
0817-07M	1020-09N	1222-10O	
0817-07N	1020-09O	1222-10P	
0817-07O	1020-09P	1222-10Q	
	1020-09Q	1222-10R	
0817-08J		1222-12L	
0817-08K		1222-12M	
0817-08L		1222-12N	
0817-08M		1222-12O	
0817-08N		1222-12P	
0817-08O		1222-12Q	
0817-08P		1222-12R	
		1222-14M	
		1222-14N	
		1222-14O	
		1222-14P	
		1222-14Q	
		1222-14R	
		1222-14S	

See Compass (CPS / CPSC) & SMT Footnotes for Additional Options and Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart Line of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

Smart (SMT)

Sample Model Number:

SMT-0814-07L-2

Designator

Number of Cells (omitted if 1)

Model List Below

SMT-0713-04G
SMT-0713-04H
SMT-0713-04J

SMT-0713-06H
SMT-0713-06J
SMT-0713-06K

SMT-0814-06H
SMT-0814-06J
SMT-0814-06K
SMT-0814-06L

SMT-0713-05G
SMT-0713-05H
SMT-0713-05J
SMT-0713-05K

SMT-0713-07H
SMT-0713-07J
SMT-0713-07K
SMT-0713-07L

SMT-0814-07H
SMT-0814-07J
SMT-0814-07K
SMT-0814-07L

See Compass (CPS / CPSC) & SMT Footnotes for Additional Options and Information



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Baltimore Aircoil Company, Inc.
Series 3000, S15E, Compass and Smart of CTI Certified Cooling Towers
CTI Certification Validation Number C11F-92R20
August 13, 2021 (Revision 20)

Compass (CPS / CPSC) & SMT **Optional Accessories and Construction – Certification Status**

Option	Suffix Note 1	CTI Certified	Capacity Adjustment Required
Low Sound Fan	Q	Yes	Yes, Note 2
Two Drift Eliminator Sets	E	Yes	Yes, Note 3
Non-Standard Motor	M	Yes	Yes, Note 4
Alternate Fan	None	Yes	No, Note 5
Combined Inlet Shields	None	Yes	Yes, Note 6
Not CTI Certified	X	No	Note 7

Footnotes:

- Typically no suffix is used for an accessory or modification that does not affect capacity.
- Low sound fans on Series Compass Cooling Towers incur a capacity reduction of 3% relative to the same unit with a standard fan. The capacity reduction incurred due to low sound fans in SMT towers is 0%-2% relative to the same unit with standard fan.
- Two drift eliminator sets on Series Compass Cooling Towers incur a capacity reduction of 2% relative to the standard unit.
- Units with non-standard motor sizes are certified only if they are listed in the Data of Record and sold at the revised capacity listed in the rating table.
- Certification on Series Compass Cooling Towers includes an alternate fan supplier with no change in capacity.
- The Combined inlet shields (CIS) option on Series Compass Cooling Towers is supplied as a customer option with the equivalent fill, without integral louvers, and will incur a capacity reduction of 2% relative to the standard unit.
- This suffix is affixed to the model numbers of units that are not CTI Certified, due to application, product accessories, or modifications.
- Multiple cell models of the single cell models above are also available and CTI certified but not listed.
- Certification is applicable to units with galvanized steel, stainless steel and FRP materials of construction.